

CHRIS LUDLE
Service Director



JEFFREY BRONOWSKI, P.E.
Water Supply Bureau Manager

EUFRANCIA G. LASH
Deputy Service Director

DANIEL HARRIGAN, MAYOR

April 24, 2020

Jim Schulte & Brent Artman
Email – brenta@artmaneng.com

Subject: Water Service
Rothrock Rd. (address number TBD)
County Parcel No. 1508366
Copley JEDD

***Due to the Covid 19 we only have one emergency crew working. The installation of the Water Service may be delayed. Once the required fees are paid, please contact Doug Zwahlen Superintendent and/or the water Service Supervisor Kevin Neitz at 330-375-2420 to get an idea of when the work could get completed.**

Dear Mr. Schulte / Artman:

The plans for the subject property have been approved by our staff contingent upon meeting all City of Akron requirements, including the following conditions:

	<u>Cost</u>	<u>Total*</u>
<u>WATER</u>		
Proposed 1-inch service	\$2,500.00	
Curb Meter Pit Intallation	\$750.00	
1-inch water meter	\$380.00	
Front foot tap-in fee	Paid	
Houseline Inspection	<u>\$836.00</u>	
Total Water Cost*		\$4,466.00

The above total is the current cost, subject to change without notice. This amount is payable by check to the "Akron Utilities Business Office", P.O. Box 3665, 146 S. High Street, Room 211, Akron, Ohio 44309-3665, Attention: New Sites, (330) 375-2445.


If you choose the monthly installment option you will receive a separate billing and you will be required to sign a Promissory Note and a Declaration of Restrictions, in addition to the regular contract. You will also be charged a document filing fee of \$150.00.

General Comments and Inspection Requirements:

1. You must submit the proposed building address to this office.
2. Contact Tommy Barnett at (330) 812-7822 for the inspection of the houseline prior to backfill. Failure to do so may result in the backfill material being removed by your houseline contractor in order to perform the required inspection.
3. At the water entry point, install a full flow 1-inch ball valve within 12 inches of entry followed by a required Reduced Pressure Backflow Prevention Assembly at 36 inches above floor and with a minimum 1-foot wall clearance. This assembly must be easily accessible for inspection, testing and maintenance purposes.
4. Contact Melissa Longfellow at (330) 375-2690 x3, for inspection of the backflow assembly upon installation.

If you have any questions please feel free to contact me at (330) 375-2690.

Sincerely,

A handwritten signature in cursive script that reads "Mark E. Eldridge". The signature is written in dark ink on a light-colored background.

Water Distribution

cc: M. Longfellow, T. Barnett, Meter Reading- K. Saunders, V. Townsend, A. Johnson, J. Boone, A. Wescott, R. Jackson, C. Kobelt, wqpws@schd.org, A. Preiksa, Siegenthaler, K. Smith, M. Krim, J. Okolish, B. Linder, B. Reaman, A. Roth, J. Bronowski, B. Angeloni